

AMENDED ARTICLE 4

dated August 22, 2001

Article 4 – Lake Level Operating Plan

The Licensee shall not operate the project reservoir at elevations greater than 1,100 feet (USGS) or less than 1,079 feet. The Licensee shall also make every reasonable effort to achieve the following minimum reservoir elevations:

Day	Minimum Elevation ¹
May 1	1,086.8 <u>1,087.6</u> feet
June 1	1,091.4 <u>1,094.0</u> feet
July 1	1,097.2 <u>1,098.0</u> feet
August 1	1,099.3 <u>1,099.0</u> feet
Labor Day	1,098.7 <u>1,098.5</u> feet

If the project is unable to be operated within these parameters, the Licensee will submit a report to the Commission within 30 days of any deviation with an explanation of why the deviation occurred and, if possible, how the situation was corrected.

¹ Lake elevations will vary between the minimum elevations indicated during each time period. Minimum elevations after Labor Day will vary from year to year depending on the runoff type (wet, dry or average); however, at no time will the reservoir be lowered below 1,079 feet. Minimum elevations may be impacted by minimum flows required in Article 5.